COMPILATION CATCH BASIN SAMPLING RESULTS PHASE I

Catch Basin Aqueous Sampling Phase One

	6/10/2014	7/1/2014	8/18/2014	Sampling Date 9/29/2014	10/23/2014	2/6/2015	6/3/2015
Catch Basin #1	I/A	I/A	I/A	I/A	N/S	0.698 ug/L	I/A
Catch Basin #3	N.D.	N.D.	0.898 ug/L	N.D	N/S	0.159 ug/L	0.107 ug/L
Man Hole #6	I/A	I/A	4.09 ug/L	6.24 ug/L	N.D	N.D.	N/S

Catch Basin Sediment Sampling Phase One

	6/10/2014	7/1/2014	8/18/2014	Sampling Date 9/29/2014	10/23/2014	2/6/2015	6/3/2015
Catch Basin #1	9.88 ppm	8.35 ppm	I/A	I/A	N/S	I/A	I/A
Catch Basin #3	4.33 ppm	5.74 ppm	12.3 ppm	I/A	N/S	I/A	I/A
Man Hole #6	I/A	I/A	I/A	I/A	N/S	I/A	N/S

Acronyms and Codes:

I/A = Sampling planned for all locations, both sediment and aqueous sampling, but insufficient amount of designated matrix to perform sampling on that date

N.D. = Non-Detectable for PCBs

N/S = Sampling not planned for all locations, specific location follow-up only